

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 442

Dates: 02/08/2026

It is certified that an inspection team headed by... Assistant Engineer

(Name of Officers with designation) from... P. H. E. Maintt Sub Division Lashka East (Gwalior)

PHED, inspected the SILVER BELLS SCHOOL, MADHUBAN NAGAR, SHIVPURI LINK ROAD, GWALIOR (Name & Address of the school) on... 29/07/2026 (date of inspection) and on the basis of water Test Report (Attached) bearing no.

442/PHED/Lab/Thaipur/Rumel Dated... 03/08/2026 30/07/2026

of PHED District water Testing Laboratory Thaipur Gwalior (PHED Lab) certified that the SILBER BELLS SCHOOL, (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also Maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T. Govt.

This certificate is Valid till... 29/07/2027

Signature With Seal :

Name

Siddharth Soni

Designation

Assistant Engineer

Name & Address of the office/Department.....

To,

SILBER BELLS SCHOOL
MADHUBAN NAGAR
SHIVPURI LINK ROAD, GWALIOR

(Name & Address of the institution)

Note : The Certificate is to be issued by authorized officer/PHED Lab/Local bodies

Silver Bells School
Principal

Public Health Engineering Department District Water- Testing Laboratory Gwalior

Test Report

Type of sample: Water Sample

Particular of sender:- Silver Bells School ward No. 59, Shivpuri Link Road Gwalior (M.P.)

Sample No.	Place of Collection and Details of Sample	Date of collection
1	Drinking Water (Ward No.2)	29.07.2026
2		
3		
4		

Particular of Sample :

Date of Receipt: 29.07.2026

Lab Reference No:

Time of Receipt: 03:35 PM

Date of Analysis: 30.07.2026

Nature of Study – Chemical and Bacteriological Analysis

PHYSICAL TEST								
S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit In the absence of alternate source				
1	Turbidity	NTU	1.0	5.0	Sample 1	Sample 2	Sample 3	Sample 4
2	Color	Cobalt	5	15	1.2	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°				-	-	-
CHEMICAL TEST								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	6.8	-	-	-
6	Alkalinity	Mg/L	200	600	82	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	30	-	-	-
8	Nitrate as No3	Mg/L	45	45	02	-	-	-
9	Total hardness	Mg/L	200	600	72	-	-	-
10	Calcium as Ca	Mg/L	75	200	17	-	-	-
11	Magnesium as mg	Mg/L	30	100	07	-	-	-
12	Iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	0.0	-	-	-
14	T.D.S.	Mg/L	500	2000	136	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.11	-	-	-
16	Sulphate as SO4	Mg/L	200	400	04	-	-	-
BACT. FEACAL TEST								
17	Total Coliform	per 100 ml	Nil		Nil	-	-	-
18	E Coli or Thermo tolerant coliforms	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate source"
- The results refer only to TEST samples and parameters TEST.
- Samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst
District Lab Gwalior

Lab In charge
P.H.E.D. Division Gwalior (M.P.)

No. 442 /PHED/ Date :- 03/01/2026